

Annexure D

BUILDING SAFETY CERTIFICATE

No. 175/01/2025

Dated 27/10/2025

It is certified that the existing building **GYAN STHALI ACADEMY** (name of the building or premises) at **SHUKLAGANJ, BHARTHANA, DIST. ETAWAH (U.P.)**

(address) Is having block (s) / Floor(s) as per details below:

Detail of Block (s) in school	0 1
No. of Floor (s) in the Block	0 3

The building is **owned**

GYAN STHALI ACADEMY, SHUKLAGANJ, BHARTHANA, ETAWAH (U.P.)

have complied with the Building safety requirements in accordance with National Building code Rules, and verified by the officers concerned of Nirman Khand 1 Lok Nirman Vibhag -Etawah (Name of Department/Govt.) on 25/10/2025 (date of inspection) in the presence of

Mr. SHIV PRASAD YADAV, Chairman of Gyan sthali Academy Shuklaganj Bharthana Etawah (U.P.) Resident OF ADDA NIHAI, ETAWAH (U.P.) (name and addresses of the Manager/Secretary or his representative) and that the building/premises is fit for occupancy for running school with effect from 27/10/2025 for a period of 03 years in accordance with rule and subject to compliance of the specific conditions as appended.

1. Two doors in every class room with the size of wide 1.60 m & height 2.60 m minimum.
2. Fire Safety System working properly.
3. Staircases and emergency exit as per norms.
4. Structural condition of Building found satisfactory.

Issued on 27/10/2025 at Etawah (U.P.) by

* Strike out whichever is not applicable. In case of block is more than six use separate sheet for detail.

Signature with Seal :

Name : Gaurav Jain

Designation : Assistant 

Name & Address of Department/Office  PWD